

www.tokoelektrikmurah.com

HP/WA : 0852-195-111-00

www.tokoelektrikmurah.com

MITSUBISHI THERMAL OVERLOAD RELAY
TYPE: 3S CB201-4-1 Ue=650V~
IEC EN 60947-4-1 Ue=420V~
Tipping Current is 125% of Dial Setting
Class 10 Ue=690V
Contacts: 1NO+1NC (8600) Ue=420V~
600V A.C. Maximum Class 10A

MITSUBISHI ELECTRIC CORPORATION
TOKYO 100-8110, JAPAN
BH73799603

⊕
PUSH TO
RESET
HAND-H
FOR AUTO RESET PUSH AND TURN THE
ROD AFTER OBTAINING THE STOP/CH
SERIAL NO.

16.4W

