

www.tokoelektrikmurah.com

HP/WA : 0852-195-111-00

Email : ipowersolution@hotmail.com



Made in China
Assembled by Schneider Electric in Indonesia

CI
Adaptation Center
Factory Sealed

Monteur / Operator :
Date: CI-2017004-4

Handwritten: 10/9-6/10
Handwritten: 4HYK0076335
Schneider Electric

1228709103
Made in China

8 Protection Center



NSX 100-160-250 F/N/H/NA

Equipped with TMODE or Micrologic trip unit
This MFC is suitable for use on a circuit capable of delivering no more than the short-circuit current rating of this MFC indicated here below.

500	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000	
25	32	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250	1600	2000	2500	3150	4000	5000	6300

Rated current and Micrologic trip unit for HP-rating
Tripping current 125%

Suitable as motor disconnect

Temperature rating 75°C	Wire size	Tightening torque Nm	Terminal kit 3p	Terminal kit 4p
16AWG to 35AWG Cu	100	11.3	LV42N242	LV42N243
12AWG to 40AWG Al	180	20	LV42N227	LV42N228
4 AWG to 1/0 AWG Cu/Al	225	26	LV42N270	LV42N271
2/0 AWG to 350kcmil Cu/Al	225	26	LV42N270	LV42N270