

CERTIFICATE OF COMPLIANCE

Certificate Number 20181204-E480011
Report Reference E480011-20171022
Issue Date 2018-DECEMBER-04

Issued to: HONEYWELL ANALYTICS ASIA PACIFIC CO LTD
7F SangAm IT Tower
434 World Cup Buk-ro Mapo-gu
Seoul 03922 KOREA

**This certificate confirms that
representative samples of**

GAS AND VAPOR DETECTION EQUIPMENT FOR USE IN
HAZARDOUS LOCATIONS; Complementary Product
Category GAS AND VAPOR DETECTION EQUIPMENT
FOR USE IN ZONE CLASSIFIED

Class I, Division 2, Groups A, B, C and D Hazardous
Locations

Gas Detection Controller, Model Touchpoint Plus,
Touchpoint Plus Expansion Unit and Touchpoint Plus
Wireless.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: See Addendum page for Standards

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20181204-E480011
Report Reference E480011-20171022
Issue Date 2018-DECEMBER-04

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Standards:

Standard No. UL 121201 NONINCENDIVE ELECTRICAL EQUIPMENT FOR USE IN CLASS I AND II, DIVISION 2 AND CLASS III, DIVISIONS 1 AND 2 HAZARDOUS (CLASSIFIED) LOCATIONS
Standard No. CSA C22.2 NO. 213-17 NONINCENDIVE ELECTRICAL EQUIPMENT FOR USE IN CLASS I AND II, DIVISION 2 AND CLASS III, DIVISIONS 1 AND 2 HAZARDOUS (CLASSIFIED) LOCATIONS
CSA 22.2 No. 152-M1984, Combustible Gas Detection Instruments



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

